

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3226-1328:116 Page 1 of 1

**CATEGORY:** Ceiling Dampers

**LISTEE:** Air Balance, 7301 International Drive, Holland OH 43528  
Contact: Chuck Schneider (419) 865-5000 FAX (419) 865-1375

**DESIGN:** Model FS2C250 ceiling damper. Intended for installation only in specific corridor ceiling constructions as provided in the installation instructions with the damper. Damper is Class II leakage rated. Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, and UL label.

**APPROVAL:** Listed as 1 hour fire-rated ceiling damper for use where air ducts penetrate or terminate at horizontal openings in the ceilings of interior corridors. Degradation test temperature is 250° F. Unit does not cover dampers intended for use in fire resistive membrane ceilings. Refer to listee's Installation Instruction Manual for details.

07-21-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JULY 21, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager